

## Inspection Report / Inspection: 1

Date <b>3/18/2010</b>	P/O. No.	Weather <b>Dry</b>	Surveyor's Name ██████████	Pipe Segment Reference	Section No. <b>416</b>
Certificate No. ██████-7-5483	Survey Customer	System Owner ██████	Date Cleaned	Pre-Cleaning <b>Jetting</b>	Sewer Category

Street 123 City Loc. details Location Code <b>Light Highway</b>	██████ <b>ES-COLLAPSED AT 320'</b> ████████████████████ ████████████████████	Use of Sewer Drainage Area Flow Control Length surveyed <b>330.00 ft</b>	Sanitary <b>PC</b>	Upstream MH <b>35</b> Downstream MH <b>36</b> Dir. of Survey <b>Downstream</b> Section Length <b>341.00 ft</b>
--	--	---	-----------------------	---

Purpose of Survey <b>Routine Assessment</b>	Joint Length <b>0.00 ft</b>
Year Laid	Dia./Height <b>8.00 inch</b>
Year Rehabilitated	Material <b>Vitrified Clay Pipe</b>
Tape / Media No. <b>RJN031810TO-12</b>	Lining Method

Add. Information :

1:795	Position	Code	Observation	MPEG	Photo	Grade
	0.00	AMH	Upstream Manhole, Survey Begins, .	00:00:00	416_1A, b	
	5.00	MWL	Water Level, 10 %of cross sectional area	00:01:17	416_2A	
	5.00	S1 DAGS	Deposits Attached Grease, 5 %of cross sectional area, from 09 to 03 o'clock, , within 8 inches of joint: YES, Start	00:02:47		M 2
	51.40	TF	Tap Factory Made, at 10 o'clock, 6", within 8 inches of joint: NO	00:02:40	416_3A	
	63.20	TF	Tap Factory Made, at 02 o'clock, 6", within 8 inches of joint: YES	00:03:17	416_5A	
	120.90	TFA	Tap Factory Made Active, at 10 o'clock, 6", within 8 inches of joint: NO	00:04:41	416_6A	
	132.80	TF	Tap Factory Made, at 02 o'clock, 6", within 8 inches of joint: NO	00:05:22	416_7A	
	185.40	TF	Tap Factory Made, at 10 o'clock, 6", within 8 inches of joint: NO	00:07:04	416_8A	
	197.60	TF	Tap Factory Made, at 02 o'clock, 6", within 8 inches of joint: NO	00:07:44	416_9A	
	260.00	TF	Tap Factory Made, at 10 o'clock, 6", within 8 inches of joint: NO	00:09:28	416_10A	
	322.40	TF	Tap Factory Made, at 10 o'clock, 6", within 8 inches of joint: NO	00:11:05	416_11A	
	325.80	F1 DAGS	Deposits Attached Grease, 5 %of cross sectional area, from 09 to 03 o'clock, , within 8 inches of joint: YES, Finish	00:11:19		M 2
	330.00	RPRD	Repair Pipe Replaced Defective, from 12 to 12 o'clock, within 8 inches of joint: YES, END SURVEY	00:11:33	416_13A	S 4

